

# Attestation

Based on test report no. 52983-002 dated 05.03.2018

for the product

**CLIMAVER PLUS R**

manufactured by

**SAINT-GOBAIN ISOVER IBÉRICA S.I.**

Evaluation of the emissions test results according to AgBB / Committee for Health-related Evaluation of Building Products (Status: 2015).

---

C-VOC (carcinogenic VOC\*)  $\leq 0.01 \text{ mg/m}^3$  (3 days after test chamber loading)  
C-VOC (carcinogenic VOC\*)  $\leq 0.001 \text{ mg/m}^3$  (28 days after test chamber loading)  
TVOC (total volatile organic compounds)  $\leq 10 \text{ mg/m}^3$  (3 days after test chamber loading)  
TVOC (total volatile organic compounds)  $\leq 1 \text{ mg/m}^3$  (28 days after test chamber loading)  
VOC (sum) without LCI  $\leq 0.1 \text{ mg/m}^3$  (28 days after test chamber loading)  
TSVOC (total semi-volatile organic compounds)  $\leq 0.1 \text{ mg/m}^3$  (28 days after test chamber loading)  
Formaldehyde  $\leq 0.01 \text{ mg/m}^3$  (28 days after test chamber loading)  
R value  $\leq 1$  (28 days after test chamber loading)

---

\* VOC = volatile organic compounds

The product **CLIMAVER PLUS R** fulfills the requirements of AgBB (Status: 2015).

Cologne, 16.03.2018

eco-INSTITUT Germany GmbH



Marc-Anton Dobaj, M.Sc. Crystalline Materials  
(Project Manager)

*This is not an eco-INSTITUT-Label certification and no confirmation about a regular inspection of the factory production. The use of this Attestation is not allowed in any product or company advertising (e.g. on the Internet)*