

Attestation

Based on test report no. 52500-001 dated 06.10.2017

for the product

CLIMCOVER ROLL ALU3

manufactured by

Saint-Gobain Isover Ibérica, S.I.

Evaluation of the emissions test results according to AgBB / Committee for Health-related Evaluation of Building Products (Status: 2015).

C-VOC (carcinogenic VOC*) $\leq 0.01 \text{ mg/m}^3$ (3 days after test chamber loading)
C-VOC (carcinogenic VOC*) $\leq 0.001 \text{ mg/m}^3$ (28 days after test chamber loading)
TVOC (total volatile organic compounds) $\leq 10 \text{ mg/m}^3$ (3 days after test chamber loading)
TVOC (total volatile organic compounds) $\leq 1 \text{ mg/m}^3$ (28 days after test chamber loading)
VOC (sum) without LCI $\leq 0.1 \text{ mg/m}^3$ (28 days after test chamber loading)
TSVOC (total semi-volatile organic compounds) $\leq 0.1 \text{ mg/m}^3$ (28 days after test chamber loading)
Formaldehyde $\leq 0.01 \text{ mg/m}^3$ (28 days after test chamber loading)
R value ≤ 1 (28 days after test chamber loading)

* VOC = volatile organic compounds

The product **CLIMCOVER ROLL ALU3** fulfills the requirements of AgBB (Status: 2015).

Cologne, 24.10.2017

eco-INSTITUT Germany GmbH



Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project Manager)

This is not an eco-INSTITUT-Label certification and no confirmation about a regular inspection of the factory production. The use of this Attestation is not allowed in any product or company advertising (e.g. on the Internet)