

Confirmation

LEED v4.1

On 12 February 2021, Eurofins Product Testing A/S received a sample of cellular polymer insulation with the product name:

URSA XPS NIII

supplied by

URSA Ibérica Aislantes S.A.

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and EN 16516 testing standards (See test report no. 392-2020-00549201_C_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2020) specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of Option 2 of LEED v4.1 BETA (July 2020) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below 1 and having a TVOC according to EN 16516 below 0.5 mg/m³ and a formaldehyde emission below 10 µg/m³ after 28 days.

25 February 2021



Pernille Krintel
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.