

Attestation

WELL Building Standard™

On the 10th of August 2023 Eurofins Product Testing A/S received a sample of levelling compound with the product name:

Perlifoc HP Eco+

supplied by

PERLITA Y VERMICULITA SLU

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the AgBB (2021) and ASTM D2369-20 test standards (See test report no. 392-2024-00364701_A_EN and 392-2024-00364702_XG_EN).

The tested product complies with the requirements of WELL v2 Feature X06 VOC Restrictions: Part 1 by complying with:

VOC emissions specifications:

- The requirements of AgBB (2021)

VOC content specifications:

- The requirement of SCAQMD Rule 1113 (Architectural coatings, 2016) for 'Fire-proofing coating' having a VOC content below 150 g/L

18 October 2024



Frederik Foged Haugaard
Analytical Service Manager



Laura Hartung Sørensen
Analytical Service Manager

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.